



AHA Facilities
Asbestos Reporting
Posted April 30, 2014

Black Lake Nursing Station

Type of Asbestos Containing Material:

- Hardened flat fiber sheet

Location at Facility:

- Exterior foundation walls

Characteristics:

- Non-friable, concentration unknown

Accessibility:

- Not exposed, below grade

Comments:

- Installed at time of construction (1986) as moisture/water barrier?

Contact:

Darcy Hegland
Facilities Manager,
Athabasca Health Authority
306 439 2620